Comparative Study of an Adsorption System Using Zeolite-Water and Silica-Gel-Water Couples: Modeling and Numerical Resolution on Simulink

Mouhamadou Lamine Cisse, Biram Dieng and Amadou Warore

Renewable Energy Research Team, Materials and Laser, Department of Physic UFR SATIC, University Alioune DIOP of Bambey Senegal (UADB), Bambey 21400, BP30, Senegal

Abstract: The objective of this work is to model initially, the different components of a single-bed adsorption system with intermittent cold production operating with hot water coming from either biogas (from methanation of animal organic waste), or a flat sensor. Then, in a second step, to the Simulink resolution to determine the evolutions of the desorption temperatures for the two working couples (T_{max} of 180 °C and 220 °C), of the adsorbed fraction (6 kg/s for the zeolite water and 4 kg/s for silica gel-water), COP (coefficient of refrigeration performance) of the order of 0.34 for silica gel-water and 0.4 for zeolite-water. These results were compared to those found in the literature for validation. It should be noted that the heat transfer fluid used is water, which has a cold production range between 0 °C and 10 °C (cooling applications) and that modeling uses the Dormand-Price OD45 method.

Key words: Simulink, zeolite, water, Dormand-Price, temperature, desorption.

Nomenclatures

ρ_s	density of the sorbent, kg/m ³
C_{ps}	Massive heat capacity of the sorbent, kJ/kg·K
ρ_g	density of the adsorbed phase, kJ/kg·K
C_{pa}	Massive heat capacity of the adsorbed phase
Δh_{ads}	Latent heat of adsorption, kJ
$(\partial w^-)/\partial t$	Variation of the adsorbed fraction
λ_e	conductivity of the sorbent. W/m ²
T_s	Temperature of the sorbent, K
h_{s-m}	Convection coefficient between the sorbent and the outside in kJ/kg
T_m	Ambient temperature
ρ_f	density of the fluid in the sorbent, kg/m ³
C_{pf}	Mass heat capacity of the fluid (adsorbed phase) in the sorbent, kJ/kg·K
T_f	Temperature of the fluid (adsorbed phase) in the sorbent, K
λ_f	Conductivity of the fluid (adsorbed phase) in the sorbent, W/m ²
T_{mc}	Average temperature in the condenser surface, K
M_m	Mass of the refrigerant in the condenser, kg
C_{pm}	Massive heat capacity of the refrigerant in the condenser, kJ/kg·K

T_c	Outside condenser temperature, K
T_{co}	Internal temperature at the condenser, K
M_e	Mass of the refrigerant in the evaporator, kg
C_{pe}	Massive heat capacity of the refrigerant in the evaporator
T_e	Average temperature in the evaporator, K
L_e	Latent heat of evaporation in the evaporator, kJ/kg·K
q_{ads}^b	Amount of adsorption heat
q_{des}^b	Quantity of desorption heat
ρ_{ch}	density of the air in the room, kg/m ³
C_{pch}	Massive heat capacity of the air in the room, kJ/kg·K
T_{ch}	Average room temperature, K
h_{ch}	convection coefficient between the chamber and the evaporator in kJ/kg

1. Introduction

The demand for energy, especially for refrigeration, is considerable [1].

Conventional cooling systems are responsible for the release of large amounts of CO₂ into the environment and the use of harmful refrigerants for the greenhouse effect and the potential for ozone depletion. Adsorption refrigeration systems have received a lot of attention because of their cold production using renewable

Corresponding author: Biram Dieng, Ph.D., professor, research field: solar and thermal energy.

energy sources. As a result, intense research over the last 15 years has been interested in solar adsorption refrigeration. Several designs of adsorption refrigeration systems have been studied.

2. Description of System

The heat input is done through hot water produced either from the thermal sensor more precisely the vacuum sensor, or from the biogas. The hot water enters the reactor (local between the two cylinders of the reactor) and transmits its heat to the adsorbent (Fig. 1). The latter starts the desorption of the refrigerant contained in it as soon as it reaches the desorption temperature. Then the desorbed fluid being in the form of steam will condense at the condenser with heat rejection. Finally, when it reaches the saturation pressure, the fluid is transmitted to the evaporator. The cooling of the adsorber during the night causes a decrease in the temperature of the adsorbent and the adsorption (production of cold). The control of the system will be by valves.

3. Mathematical Model

3.1 Adsorbent Bed

Numerous studies have focused on mathematical modeling, particularly for a cylindrical generator,

which is the typical configuration, both for the arts and the basic structure of other complex generators [2, 3]. Because solid adsorption refrigeration is essentially a phenomenon involving heat and mass transfer processes (Fig. 2), the modeling work mainly concerns adsorption performance, heat transfer in the adsorbent bed, and the transfer process coupled mass. Among the different models of adsorption performance, non-equilibrium adsorption models have become increasingly dominant [4, 5], while adsorption equilibrium models have received less attention [6, 7].

3.2 Hypotheses

The mathematical model of the physical problem stated below is based on the following assumptions:

- (1) It is considered that the adsorbed phase is liquid.
- (2) The adsorbent bed is composed of the same zeolite grains and distributed uniformly [8].
- (3) The physical properties of the liquid, the metal and the adsorbent are constant and homogeneous [9].
- (4) The thermal resistance between the metal tube and the adsorbent bed is neglected.
- (5) The adsorbent bed is homogeneous and isotropic,
- (6) The porous particles of zeolites are incompressible.

Fig. 1 Study system.

Fig. 2 Adsorption refrigeration cycle.

(7) The air flow is considered one-dimensional.

(8) The walls of the adsorber are supposed adiabatic.

Considering a transfer along the O_z axis and considering the hypotheses, we obtain:

$$\begin{aligned} (\rho_s c_{ps} + \rho_g w c_{pa}) \frac{\delta T_s}{\delta t} &= \frac{\partial}{\partial z} \left(\lambda_n * \frac{\partial T_s}{\partial z} \right) \\ &- \frac{2 * h_s - m}{D1} (T_s - T_m) \\ &+ \rho_s \Delta H_{ads} \frac{\partial \bar{w}}{\partial t} \end{aligned} \quad (1)$$

3.2.1 Condenser

Energy conservation equation for the condenser:

$$\begin{aligned} (M_m c_{pm}) \frac{\delta T_m^c}{\delta t} &= -h_m A_{mex} (T_m^c - T_c) \\ &- h_m A_{min} (T_m^c - T_{co}) \\ &+ \frac{\lambda_m}{V_m} \frac{\partial}{\partial z} \left(\frac{\partial T_m^c}{\partial z^2} \right) \end{aligned} \quad (2)$$

3.2.2 Evaporator

Energy conservation equation for the evaporator:

$$\begin{aligned} (M_E c_{pE}) \frac{\delta T_E}{\delta t} &= -L_E * M_s \frac{\partial q_{ads}^b}{\partial t} \\ &+ \left(h_f * M_s \frac{\partial q_{des}^b}{\partial t} \right) \end{aligned} \quad (3)$$

3.2.3 Cold room

Conservation equation of the room:

$$\begin{aligned} (\rho_{ch} c_{ch}) \frac{\delta T_{ch}}{\delta t} &= -U_{ch} \rho_{ch} c_{ch} \frac{\delta T_{ch}}{\delta z} \\ &- \frac{2 * h_{ch}}{de} (T_{ch} - T_E) \\ &+ \lambda_f \frac{\partial}{\partial z} \left(\frac{\partial T_{ch}}{\partial z} \right) \end{aligned} \quad (4)$$

3.2.4 Calculation of the COP

$$\begin{aligned} Q_{ev} &= M_s * L(T_e) * \int_{Ts2}^{Ta} \frac{dw(t)}{dt} * dt - M_s \\ &* C_{pf} \\ &* \left[\int_{Ts2}^{Ta} \frac{dw(t)}{dt} * dt \right] \int_{Tev}^{Tcond} dt \end{aligned} \quad (5)$$

$$Q_{des} = M_s * L(T_e)$$

$$\begin{aligned} &* \int_{Ts1}^{Tg} M_s * (C_{ps} + m_{ads}) \\ &* C_{pf} * dt \\ &+ \left[\int_{Ts2}^{Tg} M_s * Q_{st} * \frac{dw(t)}{dt} \right. \\ &* dt \left. \right] \int_{Tev}^{Tcond} dt \end{aligned} \quad (6)$$

$$COP = \frac{Q_{ev}}{Q_{des}} \quad (7)$$

3.3 Numerical Solution

The numerical method used on Matlab is that of Dormand-Price. This method is nothing more than the EULER 45 order. The simulation was made from the

blocks (Figs. 3-8) of the mathematical models. The primary data used in the numerical calculations are

given in Table 1 and the data of blocks in Table 2.

Fig. 3 Block of the adsorbent bed.

Fig. 4 Condenser block.

Fig. 5 Evaporator block.

Fig. 6 Room block.

Fig. 7 Block for the calculation of the COP.

Fig. 8 Comparison variation of the temperature desorption as a function of time.

Table 1 Input parameters of model.

Symbol	Value	Unit
Ros	896	kg/m ³
Cps	1.04	kJ/kg·K
Rog	500	kg/m ³
w	0.3	kg/kg
Cpa	0.462	kJ/kg·K
hs-m	15	W/m ² ·K
ΔHads	1,200	kJ
lamda _n	0.56	W/m·K
D1	3.45×10 ⁵	-

Table 2 Block data.

Data blocks	
M1 = Ros × Cps	K1 = 2 × hsm/D1
M2 = Rgq × Cpa	K2 = (-2 × hm/D1) * Tm
S1 = 1/lamda _n	N1 = Ros × deltaHads
T1 = T2 = 1/(Ros × delta Hads × 1,000)	
T3 = (1/(Ros × delta Hads)) × lamda _n	

4. Resultat and Discussion

Fig. 8 shows an increasing evolution of the desorption temperature until reaching $T_{hmax} = 220$ °C, 490 K for the zeolite and $T_{hmax} = 180$ °C for the silica gel. By comparing the two curves, it can be seen that the desorption temperature is much higher for the zeolite. $T_{hmax} = 180$ °C for silica gel, desorption time = 5,400 s.

The same variation is noted in Fig. 9.

Fig. 10 shows the variation of the temperature along the O_z axis of the sorbent. It gives a max value of 14

K/cm for the zeolite and 9.5 K/cm for the silica gel. It implies that the temperature of the zeolite changes from 220 °C to 203 °C along the O_z axis and the silica gel from 180 °C to 170.5 °C.

This variation is greater for zeolite, which also has better conductivity compared to silica gel.

In Fig. 11, we see a growth of the condensation temperature which reaches the maximum value of 35 °C.

Regarding the variation of the adsorbed fraction, it is increasing over time (Fig. 12). And it reaches up to 6 kg/s for zeolite and around 4 kg/s for silica gel.

Fig. 9 Temperature distribution in a tubular solar reactor, during the heating phases, according to Aroudam, El. H. [9].

Fig. 10 Comparison variation of desorption temperature along the O_z axis as a function of time.

Fig. 11 Variation of condensation temperature as a function of time.

$T_c = 35\text{ }^{\circ}\text{C}$, 308 K.

Fig. 12 Comparison variation of the adsorbed fraction as a function of time.

Fig. 13 Variation of the evaporation temperature as a function of time $T_{\text{évap}} = 275 \text{ K}$.

Fig. 14 Variation of room temperature as a function of time.

Fig. 15 Variation of the evaporator, condenser and adsorbent temperatures as a function of time.

Fig. 16 Variation of the silica-gel and zeolite COP as a function of time.

Fig. 17 Variation of the COP as a function of time [10].

From Fig. 13, the evaporator temperature is constant over time. It is equal to 2 °C.

His value is above 0 °C and allows cold production at positive temperatures.

For the temperature of the chamber (Fig. 14), it goes from 10 °C initial value to a temperature of 6.9 °C. This suggests a cold production below 8 °C (cooling applications).

The summary of the different temperatures is prescribed in Fig. 15.

Fig. 16 shows an increase in COP over time. It reaches a maximum value of 0.34 and 0.4. This number

is close to the value 0.42 given in the literature (Fig. 17). This COP is low for adsorption systems compared to absorption systems.

5. Conclusion

This modeling and simulation work made it possible to determine the evolution of temperatures in the case of a cylindrical reactor adsorption system. After inserting the input parameters of our model, these results were subsequently compared with those of other studies to measure validity.

References

- [1] Afonso, C. F. A. 2006. "Recent Advances in Building Air Conditioning Systems." *Applied Thermal Engineering* 26: 1961-71.
- [2] Zhao, H. Z., Zhang, M., Liu, Z. Y., Liu, Y. L., and Ma, X. D. 2008. "Mechanical and Experimental Study on Freeze Proof Solar Powered Adsorption Cooling Tube Using Active Carbon/Methanol Working Pair." *Energy Convers Manage* 49: 2434-8.
- [3] Mers, A. A., Azzabakh, A., Mimet, A., and Kalkha, H. E. 2006. "Optimal Design Study of Cylindrical Finned Reactor for Solar Adsorption Cooling Machine Working with Activated Carbon-Ammonia Pair." *Appl Therm Eng* 26: 1866-75.

- [4] Leong, K. C., and Liu, Y. 2004. "Numerical Modeling of Combined Heat and Mass Transfer in the Adsorbent Bed of a Zeolite/Water Cooling System." *Appl Therm Eng* 24: 2359-74.
- [5] Yang, P. Z. 2009. "Heat and Mass Transfer in Adsorbent Bed with Consideration of Non-equilibrium Adsorption." *Appl Therm Eng* 29: 3198-203.
- [6] Zhang, X. J., Liu, H. X., Wang, R. Z., and Shi, F. 2002. "Numerical Simulation of Heat Transfer in Regenerator of Solid Adsorption Refrigeration System." *Renew Energy* 26: 599-610.
- [7] Hu, J., and Exell, R. H. B. 1994. "Simulation and Sensitivity Analysis of an Intermittent Solar Powered Charcoal/Methanol Refrigerator." *Renew Energy* 4: 133-49.
- [8] Sun, L. M., Amar, N. B., and Meunier, F. 1995. "Numerical Study on Coupled Heat and Mass Transfers in an Absorber with External Fluid Heating." *Heat Recovery Systems and Chp* 15 (1): 19-29.
- [9] Aroudam, El. H. 2002. "Numerical Modelling of Heat and Mass Transfer in Adsorption Solar Reactor of Ammonia on Active Carbon." *Heat and Mass Transfer* 39 (1): 47-55.
- [10] Myat, A., Choon, N. K., Thu, K., and Kim, Y. D. 2013. "Experimental Investigation on the Optimal Performance of Zeolite-Water Adsorption Chiller." *Applied Energy* 102: 582-90.